



**CAUTION: DO NOT CONNECT MORE THAN ONE SERIES 1000-X ACTUATOR TO ONE SINGLE POLE DOUBLE THROW (SPDT) SWITCH. IF CONNECTED IN PARALLEL, DAMAGE WILL BE CAUSED TO THE MOTOR. ISOLATION RELAYS MUST BE USED IN PARALLEL CONNECTION TO MULTIPLE ACUTATORS USING A COMMON CONTROL SIGNAL INPUT.**

